



中国国家强制性产品认证证书

证书编号: 2025010302797308

认证委托人名称及地址

Mersen France SB S. A. S.

15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产者名称及地址

Mersen France SB S. A. S.

15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

生产企业名称及地址

Nolam Tunisia

rue de Nabeul lot n° 4 zone industrielle de M' Ghira ,Tunis,Tunisie

产品名称和系列、型号、规格

熔断器式隔离器

CUS10***,CMC10***; Ui:690V; Uimp:6kV; Ith:32A; Ue:AC690V,AC400V,DC400V;
Ie:AC690V:16A; AC/DC400A:32A; Iq:120kA(AC690V/400V); 50kA(DC400V) 使用类别:
AC-20B,DC-20B; 极数: 1P, 1P+N(N极可开闭), 2P, 3P, 3P+N(N极可开闭), 4P; 外壳防护等
级: IP20; 型号解释见附页

产品标准和技术要求

GB/T 14048.3-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求,特发此证。

发证日期: 2025年07月24日 有效期至: 2030年07月23日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2025010302797308

证书附页: 第 1 页 共 1 页

CMC10 a b c; CUS10 a b c

CMC10/CUS10: 系列型号

a: 极数: 1→1P, 2→2P, 3→3P, 4→4P

b: N 极: N→有, 无则表示没有

c: LED 指示灯: I→有, 无则表示没有

例如: CMC103NI:3P+N 带指示灯

序号	型号		极数	LED 指示灯
1	CUS101	CMC101	1P	否
2	CUS101I	CMC101I		是
3	CUS101N	CMC101N	1P+N	否
4	CUS101NI	CMC101NI		是
5	CUS102	CMC102	2P	否
6	CUS102I	CMC102I		是
7	CUS103	CMC103	3P	否
8	CUS103I	CMC103I		是
9	CUS103N	CMC103N	3P+N	否
10	CUS103NI	CMC103NI		是
11	CUS104	CMC104	4P	否
12	CUS104I	CMC104I		是

N 极不可拆卸

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2025010302797308

NAME AND ADDRESS OF THE APPLICANT

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND ADDRESS OF THE MANUFACTURER

Mersen France SB S.A.S.
15 rue Jacques de Vaucanson 69720 Saint Bonnet de Mure, France

NAME AND LOCATION OF THE FACTORY

Nolam Tunisia
rue de Nabeul lot n°4 zone industrielle de M'Ghira ,Tunis,Tunisie

PRODUCT NAME,MODEL AND SPECIFICATION

Fuse-disconnector

CUS10***,CMC10***; Ui:690V; Uimp:6kV; Ith:32A; Ue:AC690V,AC400V,DC400V; Ie:AC690V:16A;
AC/DC400A:32A; Iq:120kA(AC690V/400V); 50kA(DC400V) Utilization category: AC-20B,DC-20B; Poles: 1P,
1P+N(Switched N pole), 2P, 3P, 3P+N(Switched N pole), 4P; IP20; See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.24,2025

Valid until: Jul.23,2030

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2025010302797308

Appendix: Page 1 of 1

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CMC10 a b c; CUS10 a b c

CMC10/CUS10: Type designation

a: No. of poles: 1 → 1P, 2 → 2P, 3 → 3P, 4 → 4P

b: Neutral pole: N → Yes, empty → No

c: LED Indicator: I → Yes, empty → No

For example: CMC103NI:3P+N with LED indicator

序号	型号		极数	LED 指示灯
1	CUS101	CMC101	1P	否
2	CUS101I	CMC101I		是
3	CUS101N	CMC101N	1P+N	否
4	CUS101NI	CMC101NI		是
5	CUS102	CMC102	2P	否
6	CUS102I	CMC102I		是
7	CUS103	CMC103	3P	否
8	CUS103I	CMC103I		是
9	CUS103N	CMC103N	3P+N	否
10	CUS103NI	CMC103NI		是
11	CUS104	CMC104	4P	否
12	CUS104I	CMC104I		是

N 极不可拆卸

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.