



## Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

<b>Manufacturer</b>	<b>Mersen France SB SAS</b>
<b>Address</b>	15, Rue Jacques de Vaucanson, Saint Bonnet De Mure, 69720, France
<b>Type</b>	Fuses
<b>Description</b>	Fuse holders with/without indicator
<b>Trade Name</b>	CMC 8, CMC 10, CUS 10
<b>Application</b>	Marine/ Offshore applications, ENV2 category
<b>Ratings</b>	CMC8: Ue=400V, Ie=25A, Ui=690V CMC10-CUS10: Ue=690V, Ie=32A, Ui=1000V IP rating: IP20 Peak withstand current: 2,5kA - CMC8 12kA - CMC10, CUS10

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

**Previous Version:** 19/00002

The Design Appraisal Document LR2426366TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

**Matt Higgins**

Electrical & Control - Senior Specialist to  
Lloyd's Register EMEA  
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.